



Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 056083

About the qualities of a product

Certified quality: **SLIPPERINESS** according to the following test procedures:

DIN 51097 Testing of floor coverings; determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

Product: Ceramic tiles dry-pressed, EN 14411, Annex G, group B₁
type: HIMALAYA MOSAIC 29,7x29,7 cm

Producer: CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

Production plant: OPOCZNO I SP.Z O.O., Ul. Przemysłowa 5, 26-300 Opoczno, Poland

Customer: CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

Order: Z 030170478

Achieved values:

testing samples	Critical angle of slip classification according DIN 51097 (barefoot)
HIMALAYA MOSAIC 29,7x29,7 cm	22° B

The certificate is issued on the basis of the results of the tests stated in report no. 030–056082.

The certificate is extended based on the manufacturer's statement that the production technology is unchanged.

Number of pages of certificate: 1

Certificate validity: till 31st December 2020

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.



Plzeň 8th December 2017

Stamp of ZÚS Pilsen branch

Ing. Alexander Trinner

Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.