



Branch 0300 – Pilsen

# CERTIFICATE

No. 030 – 055326

## About the qualities of a product

**Certified quality:** SLIPPERINESS according to the following test procedures:

**DIN 51097** Testing of floor coverings; determination of anti – slip properties wet-loaded barefoot areas; walking method – ramp test

**DIN 51130** Testing of floor coverings determination of anti – slip properties; workrooms and fields of activities with raised slip langer, walking method – ramp test

**Product:** Ceramic tiles dry-pressed, EN 14411, Annex G, group B<sub>a</sub> type: KALLISTO ANTYSLIP 20 x 20 cm

**Producer:** CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

**Production plant:** OPOCZNO I SP.Z O.O., Ul. Przemysłowa 5, 26-300 Opoczno, Poland

**Customer:** CERSANIT S.A., Al. Solidarności 36, 25-323 Kielce, Poland

**Order:** Z 030170255

**Achieved values:**

testing samples	Critical angle of slip classification according DIN 51097 (barefoot)	Critical angle of slip classification according DIN 51130 (shoes)
		discharge volume V
KALLISTO ANTYSLIP 20 x 20 cm	22° B	30,6° R 12 V4

The certificate is issued on the basis of the results of the tests stated in report no. 030–049902.

The certificate is extended based on the manufacturer's statement that the production technology is unchanged.

Number of pages of certificate: 1

Certificate validity: till 31<sup>st</sup> July 2020

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.



Pilsen 17<sup>th</sup> July 2017

Stamp of ZÚS - branch Pilsen

**Ing. Alexander Trinner**  
Branch Director

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.